

# Watermist protection of domestic and residential occupancies – approvals approach

Louise Jackman

IWMC - 17 October 2013









## BRE Research and testing (public domain)



- 1970s+ USA residential sprinkler research
- 2000s SP, NZ, Canada experimental research
- 2000s UK experimental research
  - House fires and calorimetry fires
  - Compartment fires
  - Benchmark sprinkler fires
  - Care homes
  - Concealed/recessed
- 2007+ Watermist test
  - Prisons tests
  - Office tests
  - Domestic and residential tests

<http://www.bre.co.uk/page.jsp?id=402>





## Research findings

- Fast flaming vs slow smoky
- Tenability
- Large open space vs compartment
- Ventilation
- Nozzles spacing & flowrate
- Pass/fail criteria




# Fast flaming vs slow smoky

Simulated furniture, stylized test protocol - estimate



# Tenability - Fractional Effective Dose

- House fires (2004)
- Prison fires (2008)





## Large open space vs compartment

- In open
  - 850° C above crib
  - Not control
- In compartment, open door
  - 120° C at ceiling
  - Control



- Nozzle offset from fire 1.8 m, manual extinguishment < 20 mins



## Ventilation

- Open test scenarios
- Droplets blown, no control
- Compartment test scenarios
- Different behaviour
- Proving tests needed for ventilation scenarios



## Nozzle spacing and flowrate

– 6.25 m<sup>2</sup> spacing (5 mm/min)

– 9 m<sup>2</sup> spacing (3.5 mm/min)



## Pass/fail criteria

- Temperature criteria for timely operation
- Temperature criteria for compartment tenability
- Temperature criteria for suppression control, prevention of flashover, limited damage


## Domestic and residential simulated furniture fire test

- Add video
- <http://www.youtube.com/watch?v=o8uNq1rOA-o&feature=c4-overview&list=UU1raz2K0b4YMPOZqmN-qBIA>




bre

## Fire test protocol for domestic and residential watermist



## Fire test protocol

- DD 8458-1:2010, *Residential and domestic watermist systems – Part 1: Code of practice for design and installation*
- Fire test protocol based on fire test for residential sprinklers BS 9252
  - e.g. ceiling heights, nozzle locations, additives
- With additional consideration for:
  - fire load positions
  - ventilation conditions
  - ceiling height (optional up to 5m)







## DD 8458-1 - test arrangements

- 8 m by 4 m by 2.5 m high
- Two open doorways
- Two nozzles
- ‘Dummy’ nozzle near open doorway outside room
- Untreated plywood wall lining (12mm)
- Two polyether non FR-treated foam sheets
- A wood crib, eight layers of wood sticks on top of a heptane tray
- Cotton wicks soaked in heptane



## DD 8458-1 - five tests

- Corner
- Fuel package between two nozzles
- Fuel package beneath one nozzle
- Ventilation 1 – greatest challenge fuel package with ventilation
- Ventilation 2 – As per ventilation 1, but with the ventilation provided from the opposite end of the test room





## DD 8458-1 - acceptance criteria


- Control test fire for 10 mins (domestic) 30 mins (residential), after operation
- Acceptance criteria are:

<b>Thermocouple location</b>	<b>Maximum allowable temperature (°C)</b>
75 mm below underside of ceiling	320
1.6 m above floor	95
1.6 m above floor	55 (for not more than any 120 s interval)
Ceiling temperature - embedded 6.5 mm above the underside of the ceiling	260

- Temperatures should be declining 2 minutes after operation
- Third 'dummy' nozzle, shall not operate

# bre

## Approval



## Specifer/approver requirements

- Understand watermist and understand fire
- Confirm scope of application - room type, floor area, ceiling height, ventilation, 'standard' fire load
- Inspect fire performance reports
  - Check test house credentials
  - Check test report compliance to scope and standard
  - Check watermist system details
  - NOTE: small differences in parameters (system or test) can make a big difference to the outcome
- Check design against standards and test report
- Check component tests and approvals
- Check installation and maintenance

## Approval methodology

- Approvals are based on evidence
- Compliance with standards
- Assessment of staff, processes and systems
- Periodic audits, including testing as appropriate
- Listing and approval



## LPCB watermist approvals

- Component tests
- System verification
  - Design methodology assessment
- Fire performance tests
- Certification assessment



## Component tests

<p>Water distribution nozzles</p> <p>Water control valves</p> <p>Water check valves</p> <p>Water pipe, fittings and couplings</p>	<p>Water pumps</p> <p>Water tank and valves</p> <p>Water flow, level pressure switches</p> <p>Water manifold</p>	<p>Water strainers and filters</p> <p>Water pipe hangers</p> <p>Manual release</p> <p>Water additive</p>
---	--	--

- Examination
- Marking
- Strength test
- Internal pressure test
- Leakage test
- Corrosion tests
- Function tests
- Operation tests
- Long term ageing tests
- Thermal shock test
- Nozzle clogging test
- Pump running test


## System verification

- Bespoke systems
- Design manuals
- Hydraulic calculations
- System verification tests
- Water delivery tests with complete watermist system
- Design methodology assessment
- Design manual review



## Fire performance tests

- Manufacturers' watermist system
- Fire test protocol, DD 84589 part 1 (5 tests)
  - Simulated furniture
- Additional tests for maximum pressure and higher ceiling



## Certification assessment

- Assessment of performance requirements of components, systems and fire tests against standardised methodologies
- Assessment of quality control, ISO 9001
- On-going assessments of product, system and management through regular Factory Production Control (FPC) and product audits.



## Certificate and listing

- Product description
- Scope of application, for domestic and residential occupancies

Area type	Parameter	Limits
Bedrooms and sleeping areas Living rooms Kitchens Common rooms (some) Corridors Lofts	Floor area of compartment	32 m <sup>2</sup> or tested area
	Ceiling height	2.5 m or tested height up to 5 m
	Ventilation	≤ 1 m <sup>3</sup> /s total, from any source
	Fire load	“Normal” layouts covered



## Summary

- Watermist standard - based on comprehensive research and testing
- Watermist product testing - against application specific test protocols
- Third party approvals - increase confidence in product and system performance



# Thank you

Louise Jackman

LPCB, BRE

01923 664948

[Jackmanl@bre.co.uk](mailto:Jackmanl@bre.co.uk)

Domestic and residential fire test video  
(with and without sprinklers)

- BREVideoUK
- <http://www.youtube.com/watch?v=o8uNq1rOA-o&feature=c4-overview&list=UU1raz2K0b4YMPOZqmN-qBIA>