




Water Mist For Property Protection Purposes

Paul Morrison- Zurich Insurance

Objectives

- 3 stage approach for existing systems
 - Is it in service?
 - Will it work?
 - Is it designed right?
- Zurich Recognized Solutions
 - Listed technology
- Case Studies
 - Sauna
 - Community College
 - Industrial Oil Cooker

- Our three stage approach



Our approach



- Valves open?
- Power at pump?
- Impairments?
- Water in tank?
- Town main water supply available?

Our approach




- Service and maintenance
- Regular testing
- Pumps achieving rated duty?
- Dry systems trip tested?

Our approach

Is it in service?

Will it work?

Is it designed right?



Zurich Recognized Solutions

- May include a range of fire prevention and protection technology products
 - Not limited to active fire protection systems
 - Construction products and passive systems can be assessed



Building materials



Fire protection
devices




Fire detection
devices

Listed technology

A product certification body who has been:

- Evaluated by a third-party accreditation body
- Qualified to perform self-accreditation of the product tests they conduct




Listed technology

A product certification body who has been:

- Evaluated by a third-party accreditation body
- Qualified to perform self-accreditation of the product tests they conduct

A test protocol:

- Used for the evaluation of a product
Which is acceptable to Zurich



Listed technology

A product certification body who has been:

- Evaluated by a third-party accreditation body
- Qualified to perform self-accreditation of the product tests they conduct

A test protocol:

- Used for the evaluation of a product
- Which is acceptable to Zurich

**Zurich
Recognized
Testing
Laboratory**

**Acceptable
laboratory test
protocol**

**Zurich
Recognized
Solution**

**Zurich
recognized
property
protection
principles**

**Manufacturer's
guidelines**

A third party codes and standards:

- Recognized by Zurich for property assessment purposes
- Along with additional Zurich insights where provided

Listed technology

A product certification body who has been:

- Evaluated by a third-party accreditation body
- Qualified to perform self-accreditation of the product tests they conduct

A test protocol:

- Used for the evaluation of a product
- Which is acceptable to Zurich

**Zurich
Recognized
Testing
Laboratory**

**Acceptable
laboratory test
protocol**

**Zurich
Recognized
Solution**

**Zurich
recognized
property
protection
principles**

**Manufacturer's
guidelines**


A third party codes and standards:

- Recognized by Zurich for property assessment purposes
- Along with additional Zurich insights where provided

Guidelines Acceptable to Zurich for property assessment purposes with sufficient instructions for: design, installation, commissioning, inspection, testing, and maintenance of listed products

Case Studies – Water mist

- Sauna
- College / School
- Industrial Oil Cooker



Example - How do we consider water mist?

- NFPA 750
- BS8458
- BS8489
- CEN14972
- FM/ANSI 5560
- VdS
- SP
- DNV
- IMO

1.1* Scope. This standard contains the minimum requirements for the design, installation, maintenance, and testing of water mist fire protection systems. This standard does not provide definitive fire performance criteria, nor does it offer specific guidance on how to design a system to control, suppress, or extinguish a fire. Reliance is placed on the procurement and installation of listed water mist equipment or systems that have demonstrated performance in fire tests as part of a listing process.


Example – water mist for saunas

Local application for inception hazard



Example – water mist for saunas

Local application for inception hazard



Case study – Community College




Case study – water mist for a Community College



Fire Protection Specification Review

A review of a proposed fire protection design




Case study – water mist for a Community College Proposal statements



- Confirm costs for design, supply, installation and commissioning of our approved low pressure water mist system to all relevant areas of the scheme
- 30 minute water supply duration based on 5 nozzles (72m²) to the commercial OH1 classified hazard
- The installation and design will be fully compliant to the relevant British Standards for this development with specific referral to BS 8489:2016
- System proposed has been fully tested by BRE to both residential and commercial standards (BS 8458:2015 and BS 8489:2016)
- Low pressure water mist is an emerging technology...very few companies that can provide a system that fully meets requirements of British Standards

Case study – water mist for a Community College Proposal statements – red flags



- Confirm costs for design, supply, installation and commissioning of our **approved low pressure water mist system** to all **relevant areas** of the scheme
- 30 minute water supply duration based on 5 nozzles (72m²) to the **commercial OH1 classified hazard**
- The installation and design will be **fully compliant** to the relevant British Standards for this development with specific referral to BS 8489:2016
- System proposed has been **fully tested by BRE** to both residential and commercial standards (BS 8458:2015 and BS 8489:2016)
- Low pressure water mist is an emerging technology...very few companies can provide a system that fully meets requirements of British Standards

Case study – Community College

3 Terms and definitions

For the purposes of this part of BS 8489, the terms and definitions given in BS 8489-1 and the following apply.

- 3.1 category I system**
system that covers rooms up to and including 37 m² containing low hazard fire loads
- 3.2 category II system**
system that covers rooms above 37 m² containing low hazard fire loads
- 3.3 category III system**
system that covers rooms containing low hazard fire loads
- 3.4 low hazard occupancy**
non-storage, non-manufacturing occupancy where the quantity and/or combustibility of the content is low and fires with relatively low rates of heat release are expected, with maximum fuel loads and obstructions as indicated in 4.7 to 4.10

PERMITTED EXCEPTIONS

Protection is not deemed necessary to the following areas as stated within BS 8489, the specification received or the manufacturer's guidelines of which the system is designed and installed; therefore these have been omitted from the protected areas detailed above:

Bathrooms/Toilets/Showers/Wet Rooms <5m ²	Ceiling Voids
Cupboards, Rooms – with a floor area less than 2m ² or the smallest dimension is 1m or less	Electrical Rooms / Comms Rooms / Sub Stations
Enclosed Staircases / Vertical Shafts / Risers / Lifts	Uninhabited Loft/Roof Voids
Non Communicating / Attached Buildings	Kitchen Extraction Canopies
Crawl Spaces	External Balconies / Canopies

Table 1 Occupancies and acceptable fire test protocols for an automatic watermist system^{A)}

Occupancy	Description of occupancy	Exceptions	Fire test protocol
Apartments (where BS 8458 cannot be complied with or is not appropriate)	Lightly loaded non-storage and non-manufacturing areas with ordinary combustibles	Mat stores	BS 8489-7
Churches			FM 5560:2016, Appendix G
Concealed spaces			
Gymnasiums	Expect fire with relatively low rates of heat release in these occupancies		
Hotel bed rooms and their access (only)			
Local lending libraries			
Residential or nursing or convalescent homes where BS 8458 cannot be complied with or is not appropriate			
Offices			
Restaurant seating areas			
Schools and university classrooms			
Unused attics in low hazard premises containing no combustible contents or stored materials and no electrical or mechanical services other than lighting			

NOTE The listed test protocols are applicable with the following limited parameters.

- BS 8489-7 covers Category 1, 2 and 3 systems for:
 - fire loads ≤ 500 MJ/m² (covered in Category 3 only);
 - ceiling heights ≤ tested height up to 5 m;
 - floor area = restricted and unrestricted;
- FM 5560:2016, Appendix G covers:
 - fire loads ≤ 150 MJ/m²;
 - ceiling heights ≤ tested height up to 5 m;
 - floor area = restricted and unrestricted.

^{A)} Specific areas within buildings can be protected by watermist where relevant fire test protocols exist.

Case study

– Community College




BSI Standards Publication


Fixed fire protection systems – Industrial and commercial watermist systems

Part 7: Fire performance tests and requirements for watermist systems for the protection of low hazard occupancies


Component - nozzle



ISO 17025
ACCREDITED LABORATORY



Fire Test - partial



Design, Installation, Operation Manual (DIOM)



BSI Standards Publication

Fixed fire protection systems – Industrial and commercial watermist systems


Part 1: Code of practice for design and installation



NFPA
750
Norma sobre Sistemas de Protección contra Incendios de Agua Nebulizada
2015

Case study – Bakery

- Industrial oil cooker (deep fat fryer)
- Doughnut production
- 8m x 1.1m containing 2360L oil



Test laboratory certification

EC certificate n°: 13944/A0 EC



File Number : ACT 2000/010/001

THE SCHEDULE OF APPROVAL

1. PRODUCT DESCRIPTION :

Water Mist Fire extinguishing system for single-vat deep fat fryers.

The system consists of a pressurised cylinder assembly having a volume of 26L, which contains potable water and expellant gas (Nitrogen) at a pressure of 50 bar. The total pressure of the cylinder is from 130 to 160 bar.

2. DESIGN DRAWINGS and/or SPECIFICATIONS

2.1- As per the Manufacturer's drawings.

2.2 - As per design, installation operation and maintenance manual from the Manufacturer.

2.3 - Manual(s) for installation, use and maintenance is(are) to be stamped by the Society and supplied in the language prescribed by the Maritime National Administration to whom the ship is registered.

3. TYPE TEST REPORTS / LABORATORY RECOGNITION STATUS

Test report n° P401767 as per ISO 15371 : 2000 issued 2004-06-10 by SP, Sweden.

4. MATERIALS or COMPONENTS REQUIRED TO BE TYPE APPROVED or TYPE TESTED

None.

5. OTHER MATERIALS and/or COMPONENTS

None.

6. APPLICATION / LIMITATION OF USE

6.1- This system can protect single-vat fryers not exceeding 0.1332 m² in surface and 195 mm in depth.

6.2- Approval valid for ships having to comply with SOLAS 74 Convention, as amended, and for units having to comply with IMO Resolution A649 (The "MODU Code").

6.3- The arrangement of the system is to be submitted for each ship application.

*195 x 0.195
0.1332 x 0.195 = 0.0259
= 25.9 cm*

- Page 2



Test laboratory certification



Test report no: 081219

DFL ApS
 Svalbardvej 13, DK-5700 Svendborg, Denmark
 Tel: +45 6262 1024 - Fax: +45 6262 3661
 CVR.nr. 2921 3542

1.0 Purpose of tests:

The fire tests were conducted in a 1 x 3m tray with 150 l of frying oil to test the fire fighting performances of the VID FIRE-KILL N-pipe with BM1 nozzles installed in a Low Pressure Water Mist System.

2.0 Test hall:

DFL is an international accredited fire test laboratory. The fire test laboratory is accredited in accordance with DS/EN ISO/IEC 17025:2005 by DANAK accreditation Reg. No. 487.

The fire tests were conducted by Danish Fire Laboratories (DFL) in DFL's fire test hall at Svalbardvej 13, DK-5700 Svendborg, Denmark.


The test hall is insulated and heated. The test hall volume has a floor area of approx. 19,5m x 19,5m and a height of 15m. The test hall is equipped with an adjustable pendent ceiling. The ceiling size, position and height are adjustable. The test laboratory has water storage tanks and continuous fresh water supply, pump station with controlled water pressure supply and installations for handling of smoke and waste water.

2.1 Fire test room:

The sides of the hall were measured to 19,6m x 19,65m. The mock-up was placed in centre of the test hall.

2.2 Fire test set up:

2.2.1 Test fire was constructed as the drawing shows underneath.



150 l Fat Fryer protected with N-pipe with BM1 nozzles

Page 3 of 7

Test laboratory certification

Lloyd's Register Lloyd's Register EMEA
 71 Fenchurch Street, London, EC3M 4BS
 Telephone: 020 7423 2940 Fax: 020 7397 4246
 Email: lr-star@lr.org

Page 2 of 5
 Document number: SAS F060290
 Issue number: 1

DESIGN APPRAISAL DOCUMENT

Date: 17 October 2006 Quote this reference on all future communications
 LDSS/PAS/FITA/MF

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F060290

This Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

Underwriters Laboratories, Inc., Illinois, United States of America, Test Report No. E5204 Project 97NK12814 dated 23 July 1999.
 SP Swedish National Testing and Research Institute (Statens Provningsanstalt), Brinellgatan 4, Sweden, Fire Test Report No. 00PO02198 dated 22 May 2000.

CONDITIONS OF CERTIFICATION

1. The system has been designed in accordance with IMO MSC/Circ. 913, Annex, "Principle Requirements for the System".
2. For use in Machinery Spaces of Category A of volume greater than 500m³ for the protection of local hazards. The capacity and arrangement of spray nozzles is to be denoted in the following:
 - 2.1 Table 2-1 for passenger ships, cargo ships, yachts, high speed craft and tankers OR;
 - 2.2 When the system is provided on board LR classed inland waterway passenger ships, the capacity and arrangement of the nozzles shall be specially considered in the design stages in all cases.
3. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.
4. See General Notes.

Nozzle Designation	Max. Distance above Hazard	Min. Distance above Hazard	Spacing	Label Distance from Hazard ⁽¹⁾
931028-202	M	M	M	M
	1.0	1.75	2.25	0.56

⁽¹⁾ Minimum distance of the outer nozzles of grill are to be installed outside the protected area.



Take away messages

- Zurich Recognized Solutions Methodologies is a powerful tool to evaluate existing and proposed installations.
- It is based on basic fundamental criteria that should be expected to provide a suitable level of compliance and protection
- Zurich's goal is beyond 'Life Safety' we also want Property Protection systems.
 - People can escape a fire safely
 - The building can be occupied quickly after an event
 - Businesses can re-start operations from the same location
- Your objective may be a different one – is it fully considered ?



Paul Morrison CFPA (Europe) Dip Engtech GFireE MIFSM
Fire Protection Engineer
Risk Engineering UK

+44 (0)191 388 2675 (phone)
+44 (0)7875 885862 (mobile)
Paul.morrison@uk.zurich.com
www.zurich.com

The content of this presentation does not reflect the official opinion of the IWMA. Responsibility for the information and views expressed in the presentation [therein] lies entirely with the author(s).