



JENSEN HUGHES

Feasibility Analysis and FDS Modelling of Water Mist Fire Suppression Systems for the Protection of Aircraft Hangars

KARLI STERANKA | OCTOBER 2023

Presentation Overview

Outline


- + Motivation / Project Background
- + COTS Water Mist Literature Review Results
- + FDS Models
 - Engineering Configuration
 - FDS Inputs
 - Validation Studies
 - Results



U.S. Air Force & UMD Research Project

Research Motivation

- + Risks associated with per-and polyfluoroalkyl substances (PFAS) containing aqueous film forming foams (AFFF) [NFPA 72]
 - Toxicity
 - Biodegradability
 - Persistence
 - Persistence in wastewater treatment plants
 - Nutrient loading



COTS Literature Review Summary / Results

Identify all COTS Water Mist System

- + 15 COTS water mist manufacturers identified for evaluation
 - Low pressure ($P \leq 12$ bar)
 - Intermediate pressure ($12 \text{ bar} < P \leq 34 \text{ bar}$)
 - High pressure ($P > 34$ bar)
 - Hybrid systems (inert gas + water mist)

Literature Review Criteria

- + Marketed applications
- + Industry installations
- + Test results for class B fires
- + Relevant approvals (FM & IMO)
- + Public literature water mist characteristics


Down Selection / Final Recommendation

- + 8 manufacturers initially dismissed
- + 7 manufacturers identified as potentially successful
- + 2 manufacturers (3 nozzles) identified for Phase II
 - Nozzle A: Low pressure ceiling nozzle
 - Nozzle B: Low pressure floor nozzle
 - Nozzle C: High pressure ceiling nozzle

FDS Background / Model Overview

FDS Overview

- + Computational Fluid Dynamic (CFD) model of fire-driven fluid flow
 - Solves modified Navier Stokes equations
 - Low mach number approximation
 - Large eddy simulation (LES)



Engineering Configuration

- + Mock F-35 aircraft hangar
 - Overall dimensions: 26 m x 26 m x 12 m
 - Hangar door: 24 m x 7 m
 - Aircraft: 11m (wingspan), 16 m (length), 2 m (fuselage height), 4 m (tail height)
- + JP-8 unconfined fuel spill
 - 12 m x 24 m (assumed trench system)
- + Electrical boxes and structural steel members
- + Water mist nozzle spacing based on manufacturer recommendations

Fuel Model : JP-8 Jet Fuel unconfined spill

FDS Sub Models

- + Pyrolysis Model: *Liquid pyrolysis*
- + Combustion Model: *Infinitely fast, mixing controlled combustion*
- + Radiation Model: *Optically thin, specified radiative fraction*

FDS Inputs

Property	FDS Input Value
$C_p, \left[\frac{kJ}{kg \cdot K}\right]$	RAMP T = 20, F = 2 T = 17-, F = 2.65
$P, \left[\frac{kg}{m^3}\right]$	780
$k, \left[\frac{W}{m \cdot K}\right]$	RAMP T = 20, F = 0.115 T = 170, F = 0.085
$h_v, \left[\frac{kJ}{kg}\right]$	350
χ_r	0.05
$T_b, [^{\circ}C]$	190
Absorption Coefficient	301
Soot Yield	0.03

Lagrangian Particle Model: Nozzles

Required Inputs

- + K-factor
- + Operating Pressure
- + Offset Distance
- + Particles Per Second
- + Initial Velocity
- + Spray Angle
- + Droplet Size Distribution


Rosin-Rammler Log-Normal

$$F_v(D) = \begin{cases} \frac{1}{\sqrt{2\pi}} \int_0^D \frac{1}{\sigma D'} \exp\left(-\frac{\left[\ln\left(\frac{D'}{D_{v,0.5}}\right)\right]^2}{2\sigma^2}\right) dD' & (D \leq D_{v,0.5}) \\ 1 - \exp\left(-0.693 * \left(\frac{D}{D_{v,0.5}}\right)^\gamma\right) & (D > D_{v,0.5}) \end{cases}$$

Nozzle Characteristic Validation Simulations


Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted

Nozzle A



Droplet Size Distribution
Frequency vs diameter [μm]

Nozzle C



Initial Velocity Validation Test
Initial Velocity [m/s] vs height [m]

Nozzle A, B, & C Characteristics

Nozzle A: Low pressure ceiling mounted
 Nozzle B: Low pressure, floor pop-up
 Nozzle C: High pressure, ceiling mounted


Parameter	Nozzle A	Nozzle B		Nozzle C	
		Center Nozzle	Perimeter Nozzle	Center Nozzle	Perimeter Nozzle
K-factor $\left[\frac{L}{min*bar^{1/2}}\right]$	5.6	10	10	0.433	0.433
P [bar]	16	8	8	70	70
V_0 [m/s]		35	20	118	118
ϕ [degrees]	80	60	60	24	24
Nozzle Orientation [degrees]		-	45	-	30
D_{v50} [μm]	User specified (prev slide)	200	200	79	79
γ		2	2	2.26	2.26
σ		0.58	0.58	0.5	0.5
r_0 [m]	0.3	0.1	0.1	0.1	0.1

Droplet Size Distribution


Grid Analysis & Selection

Nozzle A: Low pressure ceiling mounted
 Nozzle B: Low pressure, floor pop-up
 Nozzle C: High pressure, ceiling mounted


Nozzle A



Nozzle B



Nozzle C



Simulated Scenarios


Nozzle A: Low pressure ceiling mounted
 Nozzle B: Low pressure, floor pop-up
 Nozzle C: High pressure, ceiling mounted

	Center Ignition Source		Side Ignition Source	
Activation Time	30 ¹ sec	50 ² sec	30 ¹ sec	50 ² sec
Nozzle A	A.1	A.2		
Nozzle B	B.1 & B.3 ³		B.2.a	B.2.b
Nozzle C	C.1	C.2		

¹based on hand calculation estimates for flame detection

²based on DoD required activation time


³Nozzle A and Nozzle B in hangar




Results Guide

Performance Criteria

- + Structural Steel members < 450 °C
Critical Heat Flux for Delamination
 - 15 kW/m² → 129 seconds
 - 25 kW/m² → 74 seconds
 - 35 kW/m² → 51 seconds
- + Control of Fire




- Legend
- Fuselage
 - Fuselage Center
 - Nose
 - LWing X = 11 & RWing X = 15
 - LWing X = 10
 - RWing X = 17.5
 - LWing X = 7.8 & RWing x = 18.2



Simulation Results A.1

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted




Performance Criteria

- + HRR is not controlled or suppressed
- + Max instantaneous structural steel temp: $> 450\text{ }^{\circ}\text{C}$
- + Max incident heat flux to plane: $> 35\text{ kW/m}^2$

Simulation Results B.2 (Nozzle B)

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted




Performance Criteria

- + Peak HRR: 25 MW +
(w/o suppression 100 MW at 60 seconds)
- + Max instantaneous structural steel temp: < 400 °C
- + Max incident heat flux to plane: < 20 kW/m²
- Ignition source center of fuel spill

Simulation Results B.2 (Nozzle B)




Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted

Temperature at 40 and 120 seconds



t=40 sec


t=120 sec



Simulation Results B.2 (Nozzle B)




Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted

Y_{H_2O} at 40 and 120 seconds




$t=40$ sec

$t=120$ sec



Simulation Results B.3 (Nozzle A&B)

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted





Performance Criteria

- + Peak HRR: < 3.2 MW
(w/o suppression 100 MW at 60 seconds)
- + Max instantaneous structural steel temp: < 60 °C
- + Max incident heat flux to plane: < 85 kW/m²
- Ignition source side of fuel spill (under plane)

Simulation Results B.3 (Nozzle A&B)


Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted

Temperature (left) and Y_{H_2O} (right) at 35 seconds



Simulation Results C.1 (Nozzle C)

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted




Performance Criteria

- + Peak HRR: < 20 MW
(w/out suppression 100 MW at 60 seconds)
- + Max instantaneous structural steel temp: < 300 °C
- + Max incident heat flux to plane: < 5 kW/m²

Simulation Results C.1 (Nozzle C)

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted


Video showing temperature, HRRPUV, and water particles



Simulation Results C.1 (Nozzle C)

Nozzle A: Low pressure ceiling mounted
Nozzle B: Low pressure, floor pop-up
Nozzle C: High pressure, ceiling mounted

Y_{H_2O} at 35, 40, and 50 seconds



Conclusions

- + Seven manufacturers (10 combined water mist systems) were identified as potential candidates to provide successful protection from pool fires in aircraft hangars
- + Water mist nozzles are highly grid dependent
- + High pressure water mist nozzles must use the parameter `PARTICLE_CFL = .TRUE`
- + Nozzle A alone is not able to suppress or extinguish a large JP-8 fuel spill
- + Nozzle B is able to prevent the fire from growing at the expected rate, but the floor nozzles alone are not able to extinguish the fire
- + Both Nozzle C and Nozzle A/B combined can extinguish this fire.
 - Simulation C.1 reaches a peak HRR of ~ 20 MW vs Simulation B.3 maintains a peak HRR less than 4 MW.
 - Floor nozzles generally cause the flame structure to deform more than the ceiling nozzles → higher heat fluxes to the aircraft

Questions?

Contact Information

Karli.Steranka@jensenhughes.com

+1 (240) 563-4208

