

# Water Mist Protection of Wind Turbine Nacelles

**Hong-Zeng (Bert) Yu**  
**FM Global**

**2022 International Water Mist Conference**  
**November 9-10, 2022**  
**Madrid, Spain**



- **\$2 million replacement cost per MW capacity**

# Wind Turbine Nacelle Fires

## Main causes:

- Lighting strike
- Electric/Mechanical Malfunction




# Current Status

- **A dedicated certification standard is unavailable for fire protection of wind turbine nacelles**
- **Fire prevention measures:**
  - **Control ignition source**
    - ✓ Avoid hot work
    - ✓ Provide braking shield
    - ✓ Prevent electrical faults
    - ✓ Isolate electrical cables from other combustibles
    - ✓ Confine combustible fluids and provide drainage
  - **Provide passive fire mitigation measures**
    - ✓ Use approved hydraulic, lubrication and heat transfer fluids
    - ✓ Use fire-resistant cables
    - ✓ Construct nacelles with noncombustible materials
    - ✓ Provide good housekeeping, regular inspection, monitoring and maintenance

# Nacelle Combustibles and Fire Hazards

- Major nacelle combustibles
  - Electrical cables
  - Ignitable liquids
    - Lubricants
      - Bearing (1.4 – 2.1 bar)
      - Gearbox (7.6 – 9.0 bar)
    - Hydraulic fluid (up to 276 bar)
    - Transformer oil (0 – 0.4 bar)
  - Nacelle enclosure construction



- Potential fire hazards
  - Pool fire
  - Spray fire
  - Spill fire
  - Oil-soaked insulation fire

# Wind Turbine Design Wind Speeds

- **IEC (International Electrotechnical Commission) wind classes:**
  - ✓ Class 1 (high wind)
  - ✓ Class 2 (medium wind)
  - ✓ Class 3 (low wind)
  - ✓ Class 4 (very low wind speed)
- **Class 1 wind turbines**
  - Typical average design wind speed for power generation: 10 m/s
  - Design wind speed for wind turbine structure:
    - 10-min average: 50 m/s
    - 3-s average: ~72 m/s

# Wind- and Temperature-driven Air Exchanges for a 4-MW Nacelle




- **4-MW wind turbines**
  - Nacelle size:  $\sim 220 \text{ m}^3$
  - Nacelle height:  $\sim 4 \text{ m}$
  - Vent openings and crevices:  $\sim 0.5 \text{ m}^2$
- **Wind-driven air exchange:  $\sim 69 \text{ m}^3/\text{min}$** 
  - Operation wind speed:  $10 \text{ m/s}$
  - Windward opening:  $0.25 \text{ m}^2$
  - Leeward opening:  $0.25 \text{ m}^2$
- **Temperature-driven air exchange:  $\sim 30 \text{ m}^3/\text{min}$** 
  - Nacelle height:  $4 \text{ m}$
  - Temperature inside the nacelle:  $100^\circ\text{C}$

**Combined air exchange:  $\sim 99 \text{ m}^3/\text{min}$**

# Existing Water Mist Protection of Enclosure Fires

## FM Approvals Standard 5560 (Parts 8 and 14 of EN 14972)



- Enclosures exceeding 260 m<sup>3</sup>
  - Minimum ceiling height: 5 m
  - Opening: 2 x 2 m

## Heptane spill fire (10<sup>th</sup> IWMC)



- 442-m<sup>3</sup> enclosure
  - Ceiling height: 7.6 m
  - Opening: 3.7 x 3.7 m




# Air Exchanges Induced by Enclosure Fires





- Machinery/turbine enclosures exceeding 260 m<sup>3</sup>: 144 m<sup>3</sup>/min
- Heptane spill fire in 442-m<sup>3</sup> enclosure: 427 m<sup>3</sup>/min

**Both are greater than 99 m<sup>3</sup>/min!**

# A Typical Nacelle Enclosure



# 4-MW Nacelle Enclosure Mockup




- Metal frame construction, with gypsum board sheathing and external insulation
- One same-size opening on each long side wall of the mockup
- Protections for different nacelle sizes to be tested in 4-MW increments

# Protection Objectives

- **Extinguish all test fires**
- **Maintain nacelle enclosure structure integrity**
  - **The outer surface temperature of gypsum boards does not exceed the failing temperature of RFP.**

# Scaling of Mockup Wall Thickness



Wall Type	Material	Density	Specific Heat
Nacelle	RFP	1550 kg/m <sup>3</sup>	1620 J/kg/°C
	Polyurethane Foam	19 – 50 kg/m <sup>3</sup>	2440 J/kg/°C
Mockup	Gypsum Board	800 kg/m <sup>3</sup>	890 – 1017 J/kg/°C
	Fiberglass Insulation	150 kg/m <sup>3</sup>	700 J/kg/°C

To correspond to 2.5-mm thick RFP and 25-mm polyurethane foam:

- Gypsum board thickness: ~10 mm
- Fiberglass insulation thickness: 9 – 24 mm

# Ignitable Liquid for Fire Tests

## Nacelles:

Nacelle Liquids	Boiling Point (°C)	Flash Point (°C)	Operating Temperature (°C)	Operating Temperature to Flash Point (°C)
Lube oil	~300	170 – 225	~95	75 – 130
Hydraulic fluid	-	148 – 315	~100	48 – 215
Transformer oil	300 – 400	> 140	~105	> 35

## Mockup:

Mockup Liquid	Boiling Point (°C)	Flash Point (°C)	Initial Temperature (°C)	Initial Temperature To Flash Point (°C)
Diesel	160 – 366	52 – 96	20	32 – 76

# Test Fires

- Diesel spray fires (FM Approvals 5560)

<b>Spray Fire Type</b>	<b>Low-Pressure Spray Fire</b>	<b>High-Pressure Spray Fire</b>
Nominal Oil Pressure	8.6 bar	150 bar
Nominal Fuel Flow Rate	1.91 kg/min	3.00 kg/min
Nominal Heat Release Rate	1.1 MW	1.8 MW


- Diesel pool fire (FM Approvals 5560): 1 x 1 m
- Diesel spill fire: 20 lpm spill from the top of the transformer mockup
- Diesel-soaked insulation fire
  - 1 m in Width x Nacelle height x Insulation Thickness

# Fire Tests – 1

- Both the long side walls of the nacelle mockup are equipped with one same size opening
- One of the two openings is subjected to the intended wind speed


## Low Pressure, Exposed, Horizontal Spray Fire

Fuel spray nozzle 100 mm above the gearbox top center, pointing horizontally toward Converter




## Low Pressure, Exposed, Vertical Spray Fire

Fuel spray nozzle 100 mm above the gearbox center, pointing up vertically




## Low Pressure, Shielded, Horizontal Spray Fire

Fuel spray nozzle 100 mm below the gearbox bottom center, pointing horizontally to the Converter



## High Pressure, Exposed, Horizontal Spray Fire

Fuel spray nozzle 100 mm above Bearing A center, pointing horizontally toward Converter






# Fire Tests – 2


## High Pressure, Exposed, Horizontal Spray Fire

Fuel spray nozzle 100 mm above Bearing B center, pointing horizontally toward Converter




## Shielded Pool Fire

1 x 1 m steel pan on the nacelle floor, centered below the raised floor



## Spill Fire




Spill fuel opening, 25 mm above the Transformer center

6 x 1.5-m steel pan, abutting nacelle wall and centered below transformer

## Oil-Soaked Insulation Fire

Nacelle high oil-soaked insulation is located based on the opening location, but not on the windward wall



# System Component Reliability Evaluation



- **Reliability evaluation of system components ( FM Approvals 5560)**
  - ✓ **Hydrostatic strength**
  - ✓ **Cycling durability**
  - ✓ **Extreme temperature (to expand from 40 – 130°F)**
  - ✓ **Corrosion/humidity/dust resistance**
  - ✓ **Vibration damage resistance (may need to expand from 0.15” vibration displacement)**
  - ✓ **Gaskets, seals and O-rings**
  - ✓ **Nozzle operation**
  - ✓ **Valve and actuator operation**
  - ✓ **Pump operation**
  - ✓ **Cylinder/tank for gas or water supply**
  - ✓ **Fire detection devices**
  - ✓ **System monitoring devices**
  - ✓ **Anti-freezing: lowest temperature and corrosion**

## **This talk has:**

- **Assessed the efficacy of water mist extinguishment of wind turbine nacelle fires.**
- **Presented an evaluation protocol for water mist protection of wind turbine nacelles, consisting of a fire test protocol and reliability evaluation of protection system components.**

**Thank you!**